



WATER PLANT SITE GRADING
SCALE 1" = 20'-0"

LEGEND

- C.T.F. EXIST. CRAMP TOP IRON FOUND
- C.I.S. EXIST. CURVED STEEL ROD SET
- EXIST. POWER POLE & GUY WIRE
- EXIST. LIGHT POLE
- EXIST. CHAINLINK FENCE
- EXIST. WOOD FENCE
- EXIST. DRAINAGE FLOORLINE
- EXIST. WEIR (HANDWOOD)
- EXIST. SEWER (HANDWOOD)
- EXIST. WATERLINE
- EXIST. SANITARY SEWER
- EXIST. WOODLINE
- EXIST. SLURRING FERTILIZER
- EXIST. WATER METER
- EXIST. WATER VALVE
- EXIST. FIRE HYDRANT
- EXIST. FACULTY
- EXIST. SINKER POLE
- FUTURE PAVED PARKING
- CONCRETE
- ASPHALT PARKING
- LANDSCAPING
- SILT FENCE
- SEWER MANHOLE
- SEWER MANHOLE

- NOTES:**
1. ALL BURIED JOINTS SHALL BE MECHANICAL JOINT W/ BEARING RESTRAINING SLANGES.
 2. SEE SPECIFICATIONS FOR PIPING SCHEDULES.
 3. PIPING IS LOCATED UNDER CONCRETE SLABS SHALL BE CONCRETE ENCASED (SEE CONC. PIP. ENCASEMENT DETAILS).
 4. PRESSURE SENSORS (UT 4-3-1-1 & UT 4-3-3-2) LOCATED IN CONTROL ROOM CONDUIT AND CHAINS HANGING TO SCOUR ARM LOCATED IN THE CONTROL ROOM OF OPERATIONS BUILDING.

DISCLAIMER

These drawings, and the information contained herein, are for general presentation purposes only, and are not intended, nor should be used, for engineering design plans.